

**Summary of Phase II Lead Testing Results
MTPS; Moorestown, NJ**

Unit #	Sample Location	Location	Fixture Code	First Test Result (ppb)	Remedial Action Performed	Second Test Results (ppb)
51	HIGH SCHOOL	B HALL WATER FOUNTAIN	HS-WF-51	32.8	Replaced with New Water Fountain	< 2.0
45	HIGH SCHOOL	C HALL WATER FOUNTAIN	HS-WF-45	17.5	Replaced with New Water Fountain	< 2.0
28	HIGH SCHOOL	MAIN OFFICE BREAK ROOM SINK	HS- S - 28	27.6	Replaced with New Water Fountain	< 2.0
	WAMS	All Locations	Misc	None > 15 ppb	Unnecessary	NA
	ADMIN BUILDING	All Locations	Misc	None > 15 ppb	Unnecessary	NA
28	UES	ROOM E 87 SINK	UES-S-28	126	Removed Aerators, Cleaned and Flushed Unit	< 2.0
1	SOUTH VALLEY	BOILER ROOM BACK FLOW	SV-POE-BF-1	99.4	Removed Aerators, Cleaned and Flushed Unit	< 2.0
3	SOUTH VALLEY	KITCHEN SINK	SV-S-3	530	Replaced old lines, valves and faucets	< 2.0
4	SOUTH VALLEY	KITCHEN SINK	SV-S-4	44.3	Replaced old lines, valves and faucets	< 2.0
13	SOUTH VALLEY	NURSES OFFICE SINK	SV-S-13	370	Replaced old lines, valves and faucets	< 2.0
14	SOUTH VALLEY	WATER FOUNTAIN NEAR ROOM 18	SV-WF-14	15.3	Replaced with New Water Fountain	< 2.0
1	MARY ROBERTS	ELECTRIC ROOM POINT OF ENTRY	MR-POE-BF-1	44.9	Removed Aerators, Cleaned and Flushed Unit	< 2.0
2	MARY ROBERTS	KITCHEN ENTRY HANDWASHING SINK	MR-S-2	15.7	Removed Aerators, Cleaned and Flushed Unit	< 2.0
8	MARY ROBERTS	LOBBY WATER FOUNTAIN	MR-WF-8	25.2	Replaced with New Water Fountain	< 2.0
12	MARY ROBERTS	R HALL WATER FOUNTAIN	MR-WF-12	18.6	Replaced with New Water Fountain	< 2.0
13	MARY ROBERTS	R HALL WATER FOUNTAIN	MR-WF-13	17	Unit Removed (Not Needed) and Lines Capped	NA
15	MARY ROBERTS	ROOM R17 WATER FOUNTAIN	MR-WF-15	19.5	Unit Removed (Not Needed) and Lines Capped	NA
17	BAKER	KITCHEN SINK	GB-17	15.2	Replaced old lines, valves and faucets	< 2.0

HEALTH & SAFETY SERVICES, Inc.

PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
Indoor Air Quality • Asbestos & Lead Management • Site Assessments

November 23, 2016

Mr. Greg McCarty
Facilities Director
Moorestown Township Public Schools
803 N. Stanwick Road
Moorestown, New Jersey 08057

Subject: District wide
Lead water sampling

Dear Mr. McCarty:

Health & Safety Services, Inc. provided the services necessary to complete 1st draw water sampling for lead contamination of drinking water throughout the school district. Approximately 268 water samples were collected throughout the district, 15 locations tested above the limit of 15 parts per billion (ppb). The table below summarized the sampling, the lead concentration limit is 15 ppb:

Moorestown HS

Sample Number	Location	Result ppb Limit = 15
28	Main office Sink	27.6
45	C-Hall water fountain	17.5
51	B Hall By B104-Water Fountain	32.8

South Valley

Sample Number	Location	Result ppb Limit = 15
1	Boiler Room POE	99.4
3	Kitchen sink	530
4	Kitchen sink	40.3
13	Nurse office sink	370
14	Outside room 18 – Water fountain	15.3

Mary Roberts

Sample Number	Location	Result ppb Limit = 15
1	Kitchen electric room – POE	44.9
2	Kitchen sink	15.7
8	Lobby water fountain	25.2
12	R-Hall water fountain	18.6
13	R-Hall Water Fountain	17.0
15	Room R-17 water fountain	19.5

HEALTH & SAFETY SERVICES, Inc.

PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
Indoor Air Quality • Asbestos & Lead Management • Site Assessments

William Allen

Sample Number	Location	Result ppb Limit = 15
<i>All sample results below 15ppb</i>		

UES

Sample Number	Location	Result ppb Limit = 15
28	Room E87 sink	126

Baker

Sample Number	Location	Result ppb Limit = 15
17	Kitchen sink	15.2

Administration building

Sample Number	Location	Result ppb Limit = 15
<i>All results below 15 ppb</i>		

If any additional information is required, please contact Health & Safety Services, Inc. at your convenience.

Respectfully,
Health & Safety Services, Inc.



James J. Proctor
President

HEALTH & SAFETY SERVICES, Inc.

PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
Indoor Air Quality • Asbestos & Lead Management • Site Assessments

Moorestown HS

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080675 **Location:**Sprinkler Room-POE **Result(ppb):**<2.00
Client No.:1

Lab No.:6080676 **Location:**I Hall-Water Fountain **Result(ppb):**<2.00
Client No.:2

Lab No.:6080677 **Location:**I Hall-Water Fountain **Result(ppb):**<2.00
Client No.:3

Lab No.:6080678 **Location:**I 105-Sink **Result(ppb):**<2.00
Client No.:4

Lab No.:6080679 **Location:**I 105-Sink **Result(ppb):**3.40
Client No.:5


Lab No.:6080680 **Location:**I 105-Sink **Result(ppb):**<2.00
Client No.:6


Lab No.:6080681 **Location:**H Hall-Water Fountain **Result(ppb):**<2.00
Client No.:7

Lab No.:6080682 **Location:**H Hall-Water Fountain **Result(ppb):**<2.00
Client No.:8

Lab No.:6080683 **Location:**Cafeteria-Water Fountain **Result(ppb):**<2.00
Client No.:9

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080684 **Location:**Cafeteria-Water Fountain **Result(ppb):**<2.00
Client No.:10

Lab No.:6080685 **Location:**Serving Line-Sink **Result(ppb):**<2.00
Client No.:11

Lab No.:6080686 **Location:**Serving Line-Sink **Result(ppb):**<2.00
Client No.:12

Lab No.:6080687 **Location:**Serving Line-Sink **Result(ppb):**2.50
Client No.:13

Lab No.:6080688 **Location:**Serving Line-Sink **Result(ppb):**2.00
Client No.:14


Lab No.:6080689 **Location:**Kitchen-Sink **Result(ppb):**<2.00
Client No.:15


Lab No.:6080690 **Location:**Kitchen-Sink **Result(ppb):**7.00
Client No.:16

Lab No.:6080691 **Location:**Kitchen-Sink; Bottle Received Empty **Result(ppb):**Sample Not Analyzed
Client No.:17
Sample not analyzed, bottle received empty

Lab No.:6080692 **Location:**Kitchen-Sink **Result(ppb):**<2.00
Client No.:18

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080693
Client No.:19

Location:Kitchen-Sink

Result(ppb):<2.00

Lab No.:6080694
Client No.:20

Location:Kitchen-Sink

Result(ppb):<2.00

Lab No.:6080695
Client No.:21
Sample not analyzed, bottle received empty

Location:Kitchen-Sink; Bottle Received Empty **Result(ppb):**Sample Not Analyzed

Lab No.:6080696
Client No.:22

Location:Kitchen-Ice Machine

Result(ppb):<2.00

Lab No.:6080697
Client No.:23

Location:Wood Shop G108-Water Fountain

Result(ppb):10.8

Lab No.:6080698
Client No.:24

Location:F Hall-Water Fountain

Result(ppb):<2.00

Lab No.:6080699
Client No.:25

Location:F Hall-Water Fountain

Result(ppb):<2.00

Lab No.:6080700
Client No.:26

Location:F Hall-Water Fountain


Result(ppb):4.70


Lab No.:6080701
Client No.:27

Location:F Hall-Water Fountain

Result(ppb):4.10

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009


Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:


Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6080702 Client No.: 28	Location: Main Office-Sink	Result(ppb): 27.6
Lab No.: 6080703 Client No.: 29	Location: A103-Sink	Result(ppb): <2.00
Lab No.: 6080704 Client No.: 30	Location: Nurse-Sink	Result(ppb): <2.00
Lab No.: 6080705 Client No.: 31	Location: A Hall Near Nurse-Water Fountain	Result(ppb): <2.00
Lab No.: 6080706 Client No.: 32	Location: A Hall Near Nurse-Water Fountain	Result(ppb): <2.00
Lab No.: 6080707 Client No.: 33	Location: Faculty Lounge E Hall-Sink	Result(ppb): 7.20
Lab No.: 6080708 Client No.: 34	Location: Home Ec.-Sink	Result(ppb): 6.60
Lab No.: 6080709 Client No.: 35	Location: Home Ec.-Sink	Result(ppb): <2.00
Lab No.: 6080710 Client No.: 36	Location: Home Ec.-Sink	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080711 **Location:**Home Ec.-Sink **Result(ppb):**<2.00
Client No.:37

Lab No.:6080712 **Location:**Home Ec.-Sink **Result(ppb):**<2.00
Client No.:38

Lab No.:6080713 **Location:**Coache's Office-Sink **Result(ppb):**<2.00
Client No.:39

Lab No.:6080714 **Location:**J Hall By Isenberg-Water Fountain **Result(ppb):**<2.00
Client No.:40

Lab No.:6080715 **Location:**J Hall By Isenberg-Water Fountain **Result(ppb):**<2.00
Client No.:41


Lab No.:6080716 **Location:**Mac Concession Stand-Sink **Result(ppb):**<2.00
Client No.:42


Lab No.:6080717 **Location:**E Hall By Girl's Locker Room-Water Fountain **Result(ppb):**<2.00
Client No.:43

Lab No.:6080718 **Location:**E Hall By Girl's Locker Room-Water Fountain **Result(ppb):**<2.00
Client No.:44

Lab No.:6080719 **Location:**C Hall-Water Fountain **Result(ppb):**17.5
Client No.:45

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080720
Client No.:46

Location:C Hall-Water Fountain

Result(ppb):11.6

Lab No.:6080721
Client No.:47

Location:CST Office-Sink

Result(ppb):<2.00

Lab No.:6080722
Client No.:48
Sample not analyzed, bottle received empty

Location:C Hall-Water Fountain; Bottles
Received Empty

Result(ppb):Sample Not Analyzed

Lab No.:6080723
Client No.:49
Sample not analyzed, bottle received empty

Location:C Hall-Water Fountain; Bottles
Received Empty

Result(ppb):Sample Not Analyzed

Lab No.:6080724
Client No.:50

Location:B Hall By B104-Water Fountain

Result(ppb):14.1

Lab No.:6080725
Client No.:51

Location:B Hall By B104-Water Fountain

Result(ppb):32.8

Lab No.:6080726
Client No.:52

Location:A Hall Near IT-Water Fountain

Result(ppb):<2.00

Lab No.:6080727
Client No.:53

Location:A Hall Near IT-Water Fountain

Result(ppb):<2.00

Lab No.:6080728
Client No.:54

Location:New A Hall 1st Floor-Water Fountain **Result(ppb):**<2.00

Please refer to the Appendix of this report for further information regarding your analysis.


Date Received: 11/11/2016

Date Analyzed: 11/18/2016

Signature:

Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080729 **Location:**New A Hall 1st Floor-Water Fountain **Result(ppb):**<2.00
Client No.:55

Lab No.:6080730 **Location:**New A Hall 1st Floor-Water Fountain **Result(ppb):**<2.00
Client No.:56

Lab No.:6080731 **Location:**Guidance Kitchen-Sink **Result(ppb):**<2.00
Client No.:57

Lab No.:6080732 **Location:**Old A Hall 2nd Floor Room 204-Sink **Result(ppb):**5.70
Client No.:58 Bubbler

Lab No.:6080733 **Location:**Old A Hall 2nd Floor Room 206-Sink **Result(ppb):**3.10
Client No.:59 Bubbler


Lab No.:6080734 **Location:**Old A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:60


Lab No.:6080735 **Location:**Old A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:61

Lab No.:6080736 **Location:**New A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:62

Lab No.:6080737 **Location:**New A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:63

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080738 **Location:**New A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:64

Lab No.:6080739 **Location:**Old A Hall 2nd Floor-Water Fountain **Result(ppb):**<2.00
Client No.:65

Lab No.:6080740 **Location:**Old A Hall 2nd Floor-Water Fountain **Result(ppb):**Sample Not Analyzed
Client No.:66
Sample not analyzed, bottle received empty

Lab No.:6080741 **Location:**Prep Room A229-Sink **Result(ppb):**<2.00
Client No.:67

Lab No.:6080742 **Location:**Prep Room A242.1-Sink **Result(ppb):**<2.00
Client No.:68


Lab No.:6080743 **Location:**Room A236-Sink **Result(ppb):**<2.00
Client No.:69


Lab No.:6080744 **Location:**In Across From B109-Water Fountain **Result(ppb):**<2.00
Client No.:70

Lab No.:6080745 **Location:**In Across From B109-Water Fountain **Result(ppb):**<2.00
Client No.:71

Lab No.:6080746 **Location:**In Across From B119-Water Fountain **Result(ppb):**<2.00
Client No.:72

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080747 **Location:**In Across From B119-Water Fountain **Result(ppb):**<2.00
Client No.:73

Lab No.:6080748 **Location:**In Across From B119-Water Fountain **Result(ppb):**<2.00
Client No.:74

Lab No.:6080749 **Location:**In Across From B119-Water Fountain **Result(ppb):**<2.00
Client No.:75

Lab No.:6080750 **Location:**Room B123.2-Sink **Result(ppb):**<2.00
Client No.:76

Lab No.:6080751 **Location:**Room E105-Sink **Result(ppb):**<2.00
Client No.:77


Lab No.:6080752 **Location:**Mac Lobby-Water Fountain **Result(ppb):**<2.00
Client No.:78


Lab No.:6080753 **Location:**Mac Lobby-Water Fountain **Result(ppb):**<2.00
Client No.:76

Lab No.:6080754 **Location:**Trainer's Office-Sink **Result(ppb):**<2.00
Client No.:80

Lab No.:6080755 **Location:**Trainer's Room-Ice Machine **Result(ppb):**<2.00
Client No.:81

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080756 **Location:**Trainer's Room-Sink **Result(ppb):**<2.00
Client No.:82

Lab No.:6080757 **Location:**Room J105-Sink **Result(ppb):**<2.00
Client No.:83

Lab No.:6080758 **Location:**Room J109-Sink **Result(ppb):**<2.00
Client No.:84

Lab No.:6080759 **Location:**J Hall Near Boy's Bathroom-Water
Client No.:85 Fountain **Result(ppb):**<2.00

Lab No.:6080760 **Location:**J Hall Near Boy's Bathroom-Water
Client No.:86 Fountain **Result(ppb):**<2.00


Lab No.:6080761 **Location:**Room J115-Sink **Result(ppb):**<2.00
Client No.:87


Lab No.:6080762 **Location:**Stadium Concession Stand-Water
Client No.:88 Fountain **Result(ppb):**<2.00

Lab No.:6080763 **Location:**Stadium Concession Stand-Sink **Result(ppb):**14.4
Client No.:89

Lab No.:6080764 **Location:**Stadium Concession Stand-Water
Client No.:90 Fountain **Result(ppb):**<2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016
Date Analyzed: 11/18/2016
Signature: 
Analyst: Mark Stewart

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6080765

Location:Blank

Result(ppb):?<2.0:1*[2]:1*;

Client No.:91

Sample not analyzed, bottle received empty

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/11/2016

Date Analyzed: 11/18/2016

Signature:



Analyst: Mark Stewart

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/18/2016
Report No.: 523690 - Lead Water
Project: Moorestown High School
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

**PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
*Indoor Air Quality • Asbestos & Lead Management • Site Assessments***

South Valley

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523669 - Lead Water
Project: South Valley Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079938 **Location:**Boiler Room-POE, 11-10-16 **Result(ppb):**99.4
Client No.:1

Lab No.:6079939 **Location:**Hall Outside Boiler Room-Water
Fountain, 11-10-16 **Result(ppb):**7.90
Client No.:2

Lab No.:6079940 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**530
Client No.:3

Lab No.:6079941 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**40.3
Client No.:4

Lab No.:6079942 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**12.4
Client No.:5

Lab No.:6079943 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**9.70
Client No.:6

Lab No.:6079944 **Location:**Across From Room 20-Water
Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:7

Lab No.:6079945 **Location:**Cafeteria-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:8

Lab No.:6079946 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:9


Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016


Date Analyzed: 11/16/2016

Signature:

Analyst:


Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523669 - Lead Water
Project: South Valley Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079947 **Location:**Room 29-Sink Bubbler, 11-10-16 **Result(ppb):**9.60
Client No.:10

Lab No.:6079948 **Location:**Room 10-Sink Bubbler, 11-10-16 **Result(ppb):**8.40
Client No.:11

Lab No.:6079949 **Location:**Next To Main Office-Water Fountain , 11-10-16 **Result(ppb):**2.00
Client No.:12

Lab No.:6079950 **Location:**Nurses Office-Sink, 11-10-16 **Result(ppb):**370
Client No.:13

Lab No.:6079951 **Location:**Outside Room 18-Water Fountain , 11-10-16 **Result(ppb):**15.3
Client No.:14

Lab No.:6079952 **Location:**Media Work Room-Sink, 11-10-16 **Result(ppb):**2.00
Client No.:15

Lab No.:6079953 **Location:**Outside The GM In Hallway-Water Fountain , 11-10-16 **Result(ppb):**<2.00
Client No.:16

Lab No.:6079954 **Location:**Room 3-Sink Bubbler, 11-10-16 **Result(ppb):**<2.00
Client No.:17

Lab No.:6079955 **Location:**Room 4-Sink Bubbler, 11-10-16 **Result(ppb):**<2.00
Client No.:18

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016


Date Analyzed: 11/16/2016

Signature:



Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523669 - Lead Water
Project: South Valley Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079956
Client No.:19

Location:Room 1-Sink Bubbler, 11-10-16

Result(ppb):<2.00

Lab No.:6079957
Client No.:20

Location:Room 2-Sink Bubbler, 11-10-16

Result(ppb):<2.00

Lab No.:6079958
Client No.:21
Sample not analyzed, bottle received empty

Location:Blank, 11-10-16

Result(ppb):Sample Not Analyzed

Lab No.:6079959
Client No.:22

Location:Art Hall-Water Fountain, 11-10-16

Result(ppb):3.40

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016

Date Analyzed: 11/16/2016

Signature:

Analyst:



Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523669 - Lead Water
Project: South Valley Elementary
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

**PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
*Indoor Air Quality • Asbestos & Lead Management • Site Assessments***

Mary Roberts

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/17/2016
Report No.: 523668 - Lead Water
Project: Mary Roberts Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079914 **Location:**Kitchen Electric Room-POE Backflow **Result(ppb):**44.9
Client No.:1

Lab No.:6079915 **Location:**Kitchen-Sink **Result(ppb):**15.7
Client No.:2

Lab No.:6079916 **Location:**Kitchen-Sink **Result(ppb):**9.60
Client No.:3

Lab No.:6079917 **Location:**Kitchen-Sink **Result(ppb):**9.30
Client No.:4

Lab No.:6079918 **Location:**Cafeteria-Water Fountain **Result(ppb):**7.20
Client No.:5


Lab No.:6079919 **Location:**Y Hall-Water Fountain **Result(ppb):**13.9
Client No.:6


Lab No.:6079920 **Location:**Y Hall-Water Fountain **Result(ppb):**<2.00
Client No.:7

Lab No.:6079921 **Location:**Lobby-Water Fountain **Result(ppb):**25.2
Client No.:8

Lab No.:6079922 **Location:**Faculty Lounge-Sink **Result(ppb):**<2.00
Client No.:9

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/17/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/17/2016
Report No.: 523668 - Lead Water
Project: Mary Roberts Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079923 **Location:**Nurses Office-Sink **Result(ppb):**2.30
Client No.:10

Lab No.:6079924 **Location:**R Hall-Water Fountain **Result(ppb):**11.2
Client No.:11

Lab No.:6079925 **Location:**R Hall-Water Fountain **Result(ppb):**18.6
Client No.:12

Lab No.:6079926 **Location:**R Hall-Water Fountain **Result(ppb):**17.0
Client No.:13

Lab No.:6079927 **Location:**Room R17-Sink **Result(ppb):**8.60
Client No.:14

Lab No.:6079928 **Location:**Room R17-Water Fountain **Result(ppb):**19.5
Client No.:15

Lab No.:6079929 **Location:**Room R16-Water Fountain **Result(ppb):**6.90
Client No.:16

Lab No.:6079930 **Location:**M Hall Across From Gym-Water **Result(ppb):**<2.00
Client No.:17 Fountain

Lab No.:6079931 **Location:**Music Room M32-Sink Bubbler **Result(ppb):**2.20
Client No.:18


Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016


Date Analyzed: 11/17/2016

Signature:

Analyst:


Chad Shaffer

Approved By:


Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/17/2016
Report No.: 523668 - Lead Water
Project: Mary Roberts Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079932 **Location:**Room A2-Sink Bubblers **Result(ppb):**5.30
Client No.:19

Lab No.:6079933 **Location:**Room A3-Sink Bubblers **Result(ppb):**3.60
Client No.:20


Lab No.:6079934 **Location:**Room A6-Sink Bubblers **Result(ppb):**3.40
Client No.:21


Lab No.:6079935 **Location:**Room A4-Sink Bubblers **Result(ppb):**<2.00
Client No.:22

Lab No.:6079936 **Location:**Room A5-Sink Bubblers **Result(ppb):**2.90
Client No.:23

Lab No.:6079937 **Location:**Blank **Result(ppb):**Sample Not Analyzed
Client No.:24
Sample not analyzed, bottle received empty

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/17/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Client: HEA198

Report Date: 11/17/2016
Report No.: 523668 - Lead Water
Project: Mary Roberts Elementary
Project No.:

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

**PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
*Indoor Air Quality • Asbestos & Lead Management • Site Assessments***

William Allen

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523667 - Lead Water
Project: William Allen Middle School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079881 **Location:**Pump Room-POE Backflow, 11-10-16 **Result(ppb):**<2.00
Client No.:1

Lab No.:6079882 **Location:**Work Room-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:2

Lab No.:6079883 **Location:**Front Lobby-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:3

Lab No.:6079884 **Location:**Front Lobby-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:4

Lab No.:6079885 **Location:**Main Office-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:5

Lab No.:6079886 **Location:**Nurse Exam Room-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:6


Lab No.:6079887 **Location:**Nurse Office-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:6A


Lab No.:6079888 **Location:**First D Hall-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:7

Lab No.:6079889 **Location:**First A Hall-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:8

Lab No.:6079890 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:9

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523667 - Lead Water
Project: William Allen Middle School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079891 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:10

Lab No.:6079892 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**2.60
Client No.:11

Lab No.:6079893 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:12

Lab No.:6079894 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:13

Lab No.:6079895 **Location:**Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:14

Lab No.:6079896 **Location:**First B Hall-Water Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:15


Lab No.:6079897 **Location:**First C Hall-Water Fountain, 11-10-16 **Result(ppb):**5.80
Client No.:16


Lab No.:6079898 **Location:**Media Hall-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:17

Lab No.:6079899 **Location:**Media Hall-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:18

Lab No.:6079900 **Location:**Girl's Locker Room-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:19

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523667 - Lead Water
Project: William Allen Middle School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079901 **Location:**Old Faculty Lounge-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:20

Lab No.:6079902 **Location:**Boy's Locker Room-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:21

Lab No.:6079903 **Location:**Cafeteria Hall-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:22

Lab No.:6079904 **Location:**Cafeteria Hall-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:23

Lab No.:6079905 **Location:**Cafeteria Hall-Porcelain Fountain, 11-10-16 **Result(ppb):**<2.00
Client No.:24

Lab No.:6079906 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:25


Lab No.:6079907 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:26


Lab No.:6079908 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:27

Lab No.:6079909 **Location:**Kitchen-Sink, 11-10-16 **Result(ppb):**<2.00
Client No.:28

Lab No.:6079910 **Location:**Kitchen-Ice Machine, 11-10-16 **Result(ppb):**<2.00
Client No.:29

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523667 - Lead Water
Project: William Allen Middle School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079911
Client No.:30

Location:Blank, 11-10-16

Result(ppb):Sample Not Received

Lab No.:6079912
Client No.:31

Location:Gym Hall, 11-10-16

Result(ppb):<2.00

Lab No.:6079913
Client No.:32

Location:Gym Hall, 11-10-16

Result(ppb):<2.00


Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016


Date Analyzed: 11/16/2016

Signature:

Analyst:


Chad Shaffer

Approved By:


Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523667 - Lead Water
Project: William Allen Middle School
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

**PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
*Indoor Air Quality • Asbestos & Lead Management • Site Assessments***

Upper Elementary School

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079809 **Location:**Boiler Room/POE Backflow, 11/10/16 **Result(ppb):**<2.00
Client No.:1

Lab No.:6079810 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:2

Lab No.:6079811 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:3

Lab No.:6079812 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:4

Lab No.:6079813 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:5


Lab No.:6079814 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:6


Lab No.:6079815 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:7

Lab No.:6079816 **Location:**Kitchen-Ice Machine, 11/10/16 **Result(ppb):**<2.00
Client No.:8

Lab No.:6079817 **Location:**Kitchen-Sink, 11/10/16 **Result(ppb):**2.70
Client No.:9

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079818 **Location:**Cafeteria-Water Fountain, 11/10/16 **Result(ppb):**<2.00
Client No.:10

Lab No.:6079819 **Location:**Faculty Lounge-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:11

Lab No.:6079820 **Location:**Room N27-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:12

Lab No.:6079821 **Location:**Room N14-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:13

Lab No.:6079822 **Location:**Room N25-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:14


Lab No.:6079823 **Location:**Room N12-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:15


Lab No.:6079824 **Location:**Room N25-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:16

Lab No.:6079825 **Location:**Room N10-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:17

Lab No.:6079826 **Location:**Room N21-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:18

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Client: HEA198

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6079827 Client No.: 19	Location: Across From WT1-Water Fountain, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079828 Client No.: 20	Location: Across From WT1-Water Fountain, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079829 Client No.: 22	Location: Room N19-Sink Bubbler, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079830 Client No.: 23	Location: Across From NT1-Water Fountain, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079831 Client No.: 24	Location: Across From NT1-Water Fountain, 11/10/16	Result(ppb): <2.00
--	--	---------------------------


Lab No.: 6079832 Client No.: 25	Location: Room N17-Sink Bubbler, 11/10/16	Result(ppb): <2.00
--	--	---------------------------


Lab No.: 6079833 Client No.: 26	Location: Room N15-Sink Bubbler, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079834 Client No.: 27	Location: Room E87-Sink, 11/10/16	Result(ppb): <2.00
--	--	---------------------------

Lab No.: 6079835 Client No.: 28	Location: Room E87-Sink, 11/10/16	Result(ppb): 126
--	--	-------------------------

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079836 **Location:**Room E85-Sink, 11/10/16 **Result(ppb):**<2.00
Client No.:29

Lab No.:6079837 **Location:**Room N22-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:30

Lab No.:6079838 **Location:**Room N8-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:31

Lab No.:6079839 **Location:**Room N6-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:32

Lab No.:6079840 **Location:**Room N4-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:33


Lab No.:6079841 **Location:**Room N2-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:34


Lab No.:6079842 **Location:**Room N24-Sink Bubblers, 11/10/16 **Result(ppb):**<2.00
Client No.:35

Lab No.:6079843 **Location:**Gym-Water Fountain, 11/10/16 **Result(ppb):**<2.00
Client No.:36

Lab No.:6079844 **Location:**Gym-Water Fountain, 11/10/16 **Result(ppb):**<2.00
Client No.:37

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079845 **Location:**Room N3-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:38

Lab No.:6079846 **Location:**Room N1-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:39

Lab No.:6079847 **Location:**Room S55-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:40

Lab No.:6079848 **Location:**Room S53-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:41

Lab No.:6079849 **Location:**Room S51-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:42


Lab No.:6079850 **Location:**Room S49-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:43


Lab No.:6079851 **Location:**Room S24-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:44

Lab No.:6079852 **Location:**Room S22-Sink Bubbler, 11/10/16 **Result(ppb):**4.80
Client No.:45

Lab No.:6079853 **Location:**Room S20-Sink Bubbler, 11/10/16 **Result(ppb):**5.80
Client No.:46

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009


Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:


Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6079854 Client No.: 47	Location: Room S39-Sink Bubbler, 11/10/16	Result(ppb): 4.30
Lab No.: 6079855 Client No.: 48	Location: Room S18-Sink Bubbler, 11/10/16	Result(ppb): <2.00
Lab No.: 6079856 Client No.: 49	Location: Across From S37-Water Fountain, 11/10/16	Result(ppb): <2.00
Lab No.: 6079857 Client No.: 50	Location: Across From S37-Water Fountain, 11/10/16	Result(ppb): <2.00
Lab No.: 6079858 Client No.: 51	Location: Media Office-Sink, 11/10/16	Result(ppb): <2.00
Lab No.: 6079859 Client No.: 52	Location: Nurses Office-Sink, 11/10/16	Result(ppb): <2.00
Lab No.: 6079860 Client No.: 53	Location: Room S1-Sink Bubbler, 11/10/16	Result(ppb): <2.00
Lab No.: 6079861 Client No.: 54	Location: Room S3-Sink Bubbler, 11/10/16	Result(ppb): <2.00
Lab No.: 6079862 Client No.: 55	Location: Room S35-Sink Bubbler, 11/10/16	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079863 **Location:**Room S33-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:56

Lab No.:6079864 **Location:**Room S31-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:57

Lab No.:6079865 **Location:**Room S29-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:58

Lab No.:6079866 **Location:**Room S27-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:59

Lab No.:6079867 **Location:**Room S14-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:60


Lab No.:6079868 **Location:**Room S25-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:61


Lab No.:6079869 **Location:**Room S6-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:62

Lab No.:6079870 **Location:**Room S8-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:63

Lab No.:6079871 **Location:**Room S10-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:64

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079872 **Location:**Room S13-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:65

Lab No.:6079873 **Location:**Room S17-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:66

Lab No.:6079874 **Location:**Room S12-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:67

Lab No.:6079875 **Location:**Across From Room S19-Water Fountain, 11/10/16 **Result(ppb):**<2.00
Client No.:68

Lab No.:6079876 **Location:**Across From Room S19-Water Fountain, 11/10/16 **Result(ppb):**<2.00
Client No.:69


Lab No.:6079877 **Location:**Room S19-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:70


Lab No.:6079878 **Location:**Room S23-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:71

Lab No.:6079879 **Location:**Room S21-Sink Bubbler, 11/10/16 **Result(ppb):**<2.00
Client No.:72

Lab No.:6079880 **Location:**Blank, 11/10/16 **Result(ppb):**Sample Not Analyzed
Client No.:73
Sample not analyzed, bottle received empty

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523666 - Lead Water
Project: Moorestown Upper Elementary School
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

**PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
*Indoor Air Quality • Asbestos & Lead Management • Site Assessments***

George Baker

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009


Report Date: 11/16/2016
Report No.: 523665 - Lead Water
Project: George Baker Elementary
Project No.:


Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 6079784 Client No.: 1	Location: Rear Pump Rm, POE	Result(ppb): 5.10
Lab No.: 6079785 Client No.: 2	Location: Rear Hall Between Bathrooms, Water Fountain	Result(ppb): <2.00
Lab No.: 6079786 Client No.: 3	Location: Faculty Lounge, Sink	Result(ppb): 2.60
Lab No.: 6079787 Client No.: 4	Location: Media Work Rm, Sink	Result(ppb): <2.00
Lab No.: 6079788 Client No.: 5	Location: Rm 18, Sink Bubbler	Result(ppb): <2.00
Lab No.: 6079789 Client No.: 6	Location: Rm 23, Sink Bubbler	Result(ppb): <2.00
Lab No.: 6079790 Client No.: 7	Location: Rm 20, Sink Bubbler	Result(ppb): <2.00
Lab No.: 6079791 Client No.: 8	Location: Rm 25, Sink Bubbler	Result(ppb): <2.00
Lab No.: 6079792 Client No.: 9	Location: Rm 22, Sink Bubbler	Result(ppb): <2.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523665 - Lead Water
Project: George Baker Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079793 **Location:**Rm 27, Sink Bubbler **Result(ppb):**<2.00
Client No.:10

Lab No.:6079794 **Location:**Rm 24, Sink Bubbler **Result(ppb):**<2.00
Client No.:11

Lab No.:6079795 **Location:**Rm 29, Sink Bubbler **Result(ppb):**<2.00
Client No.:12

Lab No.:6079796 **Location:**Rm 26, Sink Bubbler **Result(ppb):**<2.00
Client No.:13

Lab No.:6079797 **Location:**Rm 31, Sink Bubbler **Result(ppb):**<2.00
Client No.:14

Lab No.:6079798 **Location:**Rm 28, Sink Bubbler **Result(ppb):**3.40
Client No.:15

Lab No.:6079799 **Location:**Rm 33, Sink Bubbler **Result(ppb):**<2.00
Client No.:16

Lab No.:6079800 **Location:**Kitchen, Sink **Result(ppb):**15.2
Client No.:17

Lab No.:6079801 **Location:**Cafeteria, Water Fountain **Result(ppb):**11.2
Client No.:18

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016

Date Analyzed: 11/16/2016

Signature:



Analyst: Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523665 - Lead Water
Project: George Baker Elementary
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079802 **Location:**Main Lobby, Water Fountain **Result(ppb):**<2.00
Client No.:19

Lab No.:6079803 **Location:**Outside Nurse Office In Hallway,
Water Fountain **Result(ppb):**<2.00
Client No.:20

Lab No.:6079804 **Location:**Nurses Office, Sink **Result(ppb):**<2.00
Client No.:21


Lab No.:6079805 **Location:**Hallway By Rm 3, Water Fountain **Result(ppb):**3.20
Client No.:22


Lab No.:6079806 **Location:**Hallway By Rm 7, Water Fountain **Result(ppb):**<2.00
Client No.:23

Lab No.:6079807 **Location:**Rm 9, Water Fountain **Result(ppb):**2.00
Client No.:24

Lab No.:6079808 **Location:**Blank **Result(ppb):**Sample Not Analyzed
Client No.:25
Sample Not Analyzed, Bottle received empty

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016
Date Analyzed: 11/16/2016
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/16/2016
Report No.: 523665 - Lead Water
Project: George Baker Elementary
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

HEALTH & SAFETY SERVICES, Inc.

PO Box 365 • Berlin, NJ 08009 • (856) 452-1311 • info@hssenv.com
Indoor Air Quality • Asbestos & Lead Management • Site Assessments

Administration Building

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/17/2016
Report No.: 523664 - Lead Water
Project: Moorestown Administration Building 11/10/16
Project No.:

Client: HEA198

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:6079780
Client No.:2

Location:Back Hall Sink

Result(ppb):<2.00

Lab No.:6079781
Client No.:3

Location:Back Hall Water Fountain

Result(ppb):<2.00

Lab No.:6079782
Client No.:4

Location:Superendant Bathroom Sink

Result(ppb):<2.00

Lab No.:6079783
Client No.:5
Bottle received empty

Location:Blank

Result(ppb):Sample Not Analyzed


Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 11/10/2016

Date Analyzed: 11/17/2016

Signature:

Analyst:


Chad Shaffer

Approved By:



Frank E. Ehrenfeld, III

Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Health & Safety Services, Inc
PO Box 365
Berlin NJ 08009

Report Date: 11/17/2016
Report No.: 523664 - Lead Water
Project: Moorestown Administration Building 11/10/16
Project No.:

Client: HEA198

Appendix to Analytical Report:

Customer Contact: Al Oswald
Analysis: AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: cdavis@iatl.com
iATL Account Representative: Pete Lesniak
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:
- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010
- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)
Certification:
- NYS-DOH No. 11021
- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.